



Jann Reed <jreed@ci.sandy.or.us>

## Fwd: Mobile Food Unit Application has been approved.

1 message

**Nick Haddox** <nick.haddox14@gmail.com>  
To: planning@ci.sandy.or.us

Mon, Jun 22, 2026 at 1:40 PM

----- Forwarded message -----

From: **Clackamas Fire District #1** <noreply@formresponse.com>  
Date: Mon, Jun 22, 2026, 1:10 PM  
Subject: Mobile Food Unit Application has been approved.  
To: <nick.haddox14@gmail.com>

Your request has been approved.

[mike.boumann@clackamasfire.com](mailto:mike.boumann@clackamasfire.com)

Clackamas Fire is in approval of the Baked and Loaded food cart opening up for business.

### Mobile Food Unit Application

Mobile Food Unit Owner Name:	Nicholas Haddox
Name of Business:	Baked & Loaded LLC
Owner Cell#:	(313) 735-2122
Owner Email:	<a href="mailto:nick.haddox14@gmail.com">nick.haddox14@gmail.com</a>
Site Location:	Sandlandia, 38424 Pioneer Blvd, Sandy, OR

Is your Mobile Food Unit blocking at fire department access road?

Is your Mobile Food Unit 5' away from lot lines, buildings or structures, other food carts, combustible materials, vehicles?

(Oregon Fire Code section 319.2.4)

Are you using a Generator? If "yes", the following applies per Oregon Fire Code section 319.2.6; No refueling while operating, Not operated in an enclosed area, Vehicle-mounted generators are installed, used and maintained according to listing and manufacturer's instructions.

No, I am not using a generator

All Exits must meet the following Oregon Fire Code section 319.2.7; Means of egress are clear and unobstructed, two exits are provided, and customer service window is appropriately sized for egress.

Yes, I acknowledge above requirements are met

All electrical appliances and devices meet the following Oregon Fire Code section 319.2.8; used and maintained in accordance with NFPA 70, listed and labeled, modified or damaged electrical has been repaired or replaced, approved covers for all switches, electrical outlet boxes, and proper use of temporary wiring.

Yes, I acknowledge all electrical meets this section

Cooking Oil Storage meets the following Oregon Fire Code section 319.2.12.3; metallic and nonmetallic cooking oil storage system components shall include, but are not limited to, piping, connections, fittings, valves, tubing, hose, pumps, vents, and other related components used for the transfer of cooking oil.

Not applicable for my mobile food unit

LP Gas Systems meet Oregon Fire Code section 319.2.13; components inspected annually, maximum aggregate volume of 200 pounds, containers securely mounted and restrained, container manufacture in compliance with NFPA 58, container installation complies with NFPA 58, system piping protected to prevent tampering, impact damage, and damage

Yes, I acknowledge the LP Gas System meets this section requirements

from vibration, listed LP gas alarm installed.

Compressed Natural Gas Systems meet Oregon Fire Code Section 319.2.15; containers supply only cooking fuel, meets maximum aggregate volume, container is properly protected, container constructed properly, containers supply transportation and cooking fuel, piping properly protected, methane alarms present.

Not applicable for my mobile food unit, I don't use CNG

Solid Fuel Cooking meets Oregon Fire Code Section 319.16; Dedicated hood system provided, 2.5 gallon water extinguisher and Class K extinguisher, fuel properly located, outdoor storage, fuel properly separated, ash properly removed, carbon monoxide alarms as required.

Not applicable for my mobile food unit, I don't cook with Solid Fuel

Fire protection systems and devices tested by qualified professional

Inspection, Testing, and Maintenance per Oregon Fire Code Section 319.2.18, check all that apply to your Mobile Food Unit:

Exhaust system inspected, tested, and maintained every six months

Fuel gas system tested or replaced every 5-12 years

No appliances connected to fuel gas systems without a current satisfactory fuel gas inspection

Does your Mobile Food Unit have a Hood Suppression System:

Yes

Upload a copy of the hood suppression system test documentation here (you may take a photo as well):

[2026-04-14\\_PDX-Cart-Builders\\_BRForms\\_Nick Cart\\_3647.pdf](#)

Provide a copy of the County Health Department certificate:

[generate\\_1167.pdf](#)

Signature

A handwritten signature in black ink, appearing to read "N. Zedex". The signature is written in a cursive style with a large initial "N" and a period following it.

Date

06-22-2026