

CITY HALL IMPROVEMENTS – SAFETY PROVISIONS / MODIFY OFFICE SPACES

Addendum # 1

1. Specifications/Finish Schedule for Carpet/Flooring, Paint, and Baseboards?

Paint Color:

Base Wall Color: 0279 Garden Country (Sherwin Williams)

Trim Color: 0263N Country Charm (Miller Paint)

Column Color: E0123N Turned Earth (Miller Paint)

(paint can labels can be provided by City staff)

Flooring: Shaw Carpet: Style 54564 Static (59269968) Color: 00406 CO-Channel

<https://www.georgiacarpet.com/products/shaw-philadelphia-interference-static-54564-commercial-carpet-tile.html>

Baseboards: Shaw Carpet / Style: Emphatic

** Staff still has remnants available.*

2. Transaction Window:

a. Is there a specific bullet resistance rating required?

Answer: Ballistic Level 3 (1.25-inches thick). All safety glass shall be 1.25-inches thick.

b. Please confirm there are four (4) transaction windows and the location.

Answer: Yes, four (4) transaction windows, two (2) at each front counter.

c. Please confirm the size of the transaction window.

Answer: 24-inches wide by 36-inches in height.

3. Hollow Metal Door:

a. The Armortex cut sheet notes a flush door. The door schedule on sheet A2.1 notes “Full Lite”. Please confirm what one is intended.

Answer: 16 GA flush steel door, no glass glazing.