



NOTES:

1. SANITARY MAIN, LATERAL AND FITTINGS SHALL BE LIKE MATERIALS. ONLY MANUFACTURED FITTINGS SHALL BE USED.
2. MINIMUM DEPTH AT RIGHT OF WAY OR EASEMENT LINE SHALL BE 4 FEET.
3. MARKER POSTS AND BLOCKING SHALL BE TREATED WOOD. POST SHALL BE 2" x 4" FIR. POST TO EXTEND 12" MINIMUM ABOVE FINISH GRADE AND EXPOSED AREA SHALL BE PAINTED FLOURESCENT GREEN.
4. INSTALL CLEANOUT WHEN SPECIFIED IN PERMIT OR PLAN REVIEW. REFER TO SANDY052.DWG (DRAWING 310) FOR CLEANOUT DETAIL.
5. LAY BUILDING SEWER AT MAX. 45° FROM HORIZONTAL TO ACHIEVE REQUIRED DEPTH AT PROPERTY LINE WHEN MINIMUM SLOPE RESULTS IN EXCESSIVE DEPTH.

CITY OF SANDY	
SHALLOW TRENCH SERVICE CONNECTION, BLOCKING, AND MARKERS	
DATE: DEC 2003	DRAWING NO. 308