



–MINIMUM 10 FT. HORIZONTAL SEPARATION REQUIRED FOR PARALLEL WATER AND SANITARY SEWER LINES.

–IF HORIZONTAL SEPARTION CANNOT BE MAINTAINED AND IN THE CASE OF A WATER LINE CROSSING OVER A SANITARY SEWER A MINIMUM OF 1.5’ (18”) VERTICAL SEPARATION IS REQUIRED.

–WHEN THESE CLEARANCES CANNOT BE MAINTAINED; WHEN WATER LINE IS IN ZONE 2 AND/OR FOR WATER LINES CROSSING UNDER SANITARY SEWERS REFER TO OAR 333–061–0050(9) FOR CASE–BY–CASE DETERMINATION. REQUEST DETERMINATION FROM PROJECT ENGINEER.

- ZONE 1: ONLY CROSSING RESTRICTIONS APPLY.
- ZONE 2: CASE–BY–CASE DETERMINATION REQUIRED.
- ZONE 3: PARALLEL WATER LINE PROHIBITED.
- ZONE 4: PARALLEL WATER LINE PROHIBITED.

CITY OF SANDY

SANITARY AND WATER
SEPARATION RESTRICTIONS

DATE:
JULY 2004

DRAWING NO.
SANDY066.DWG