



NOTES:

1. STANDARD PRECAST MANHOLE SECTION DIAMETER SHALL BE 48". USE 42" IF SPECIFIED BY THE ENGINEER.
2. ALL CONNECTING PIPES SHALL HAVE A FLEXIBLE JOINT WITHIN 18" OF MANHOLE WALL (IF BOOT IS NOT USED).
3. SEE MANHOLE BASE SECTION DRAWING FOR BASE DETAILS.
4. MAXIMUM DISTANCE FROM TOP STEP TO FINISH GRADE SHALL NOT EXCEED 24".

CITY OF SANDY	
STORM AND SANITARY SEWER MANHOLE	
DATE: NOV 1997	DRAWING NO. 315