



YOUR DRINKING WATER CONSUMER CONFIDENCE REPORT FOR CALENDAR YEAR 2020

General Water System Information

Questions regarding the City's water supply, treatment and quality control may be directed to: Mike Walker, Public Works Director at 503-489-2162, mwalker@ci.sandy.or.us. The City actively seeks public participation in decisions affecting your drinking water. City Council meetings are held at 7:00 PM on the first and third Mondays of each month at Sandy City Hall, 39250 Pioneer Blvd. Sandy, OR 97055. Agendas for upcoming City Council meetings and minutes of past Council meetings may be found on our website: www.ci.sandy.or.us.

Water Source Information

The City of Sandy has three water sources. During the spring, fall and winter approximately 50% of the City's supply is purchased from the Portland Water Bureau. The remainder of our supply comes from Brownell Springs and Alder Creek. During the summer when demand increases each source provides approximately one-third of the total supply.

Definitions Useful in Interpreting This Report

Disinfection By-products - compounds formed by a reaction between the chlorine used to disinfect water and any organic material remaining in the water or the piping system.

None-Detected (ND) - laboratory analysis indicates that the constituent is not present at or above the detection limit of the equipment and analysis method.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million

Parts per billion (ppb) - one part per billion

PicoCuries per liter (pCi/l) - one trillionth of a Curie (a measure of the decay of Radium)

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level - the concentration of a contaminant, which if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. MCL's are set at very stringent levels. **To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for 70 years to have a one-in-a-million chance of having the described health effect.**

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Turbidity - is the measure of "cloudiness" or suspended particles in water. Particles that create turbidity can provide a growth medium for bacteria and hinder the effectiveness of treatment methods and disinfection processes.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by visiting the Environmental Protection Agency's Safe Drinking Water Hotline site:

<https://www.epa.gov/ground-water-and-drinking-water/safe-drinking-water-hotline>

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline site: <https://www.epa.gov/ground-water-and-drinking-water/safe-drinking-water-hotline>

The table on the reverse side summarizes analyses of your drinking water performed in calendar year 2020 (January 1, 2020 through December 31, 2020).

CONTAMINANT	MAX. AMT. DETECTED	(MCL)	(MCLG)	SOURCE OF CONTAMINATION
Disinfection By-Products (Distribution System - All Sources)				
Total Trihalomethanes (TTHM)	0.0718 mg/l	0.080 mg/l	N/A	Reaction between chlorine and organics in source water
Total Haloacetic Acids (HAA5)	0.0918 mg/l	0.060 mg/l	N/A	Reaction between chlorine and organic carbon in water
Alder Creek Source (Entry Point A)				
Turbidity ¹	0.3 NTU	0.3 NTU in 95% of samples 1.0 NTU at any one time	< 0.3 NTU	Soil erosion and stream sediments
Nitrate	0.253 mg/l	10.0 mg/l	N/A	Naturally present in the environment
Alkalinity	43.0 mg/l	N/A	N/A	Naturally present in the environment
Barium	0.00226 mg/l	2 mg/l	2 mg/l	
Fluoride	0.033 mg/l	4 mg/l	4 mg/l	
Sodium	4.7 mg/l	N/A	N/A	
Brownell Springs Source (Entry Point B)				
Turbidity ¹	0.154 NTU	0.3 NTU in 95% of samples 1.0 NTU at any one time	< 0.3 NTU	Soil erosion and stream sediments
Barium	0.00068 mg/l	2 mg/l	2 mg/l	Naturally present in the environment
Fluoride	0.042 mg/l	4 mg/l	4 mg/l	
Sodium	4.7 mg/l	N/A	N/A	
Portland Water Bureau Source (Entry Point C)				
Turbidity ¹	3.31 NTU	Cannot exceed 5 NTU more than 2 times in 12 months	N/A - Unfiltered Source	Soil erosion and stream sediments
Nitrate	0.87 mg/l	N/A	N/A	Naturally present in the environment
Arsenic (ppb)	0.092 ppb	10 ppb	0 ppb	
Barium	0.0097 mg/l	2 mg/l	2 mg/l	
Copper ²	0.262 ppm	N/A	N/A	
Fluoride	0.17 mg/l	4 mg/l	4 mg/l	
Lead (ppb) ²	13.8 ppb	N/A	0 ppb	Found in mineral deposits
Radon piC/l	340 piC/l	N/A	N/A	
Total Organic Carbon (TOC)	1.7 mg/l	N/A	N/A	Naturally present in the environment
<i>Cryptosporidium</i> ³	0.08 oocysts/liter - maximum concentration detected (39 detects in 185 fifty-liter samples)			
Sodium (ppm)	13.0 ppm	N/A	N/A	Found in mineral deposits

¹Turbidity is monitored at all water sources on a round-the-clock basis in order to determine the effectiveness of treatment and to comply with regulatory requirements. When turbidity from the Portland Water Bureau source approaches 1 NTU we stop taking water from that source.

²Lead and Copper are not found in source waters but are detected when low pH water reacts with lead and copper in household plumbing. Sandy's Lead and Copper detections have always been below the action level so we only have to sample every three years (last was in 2019).

³For more information on *Cryptosporidium* detections in the Portland Water Bureau source please visit <https://www.portland.gov/water/water-quality/cryptosporidium#toc-portland-s-cryptosporidium-reports>

It is important to point out that we monitor for many contaminants other than those listed in this table, (over 60 from all sources in 2020). Only contaminants that are detected are listed in this table. In addition to these analyses, the City collects a minimum of ten samples every month from the distribution system, (the pipes that deliver water to your home) to test for coliform contamination.

Water Quality Violations

The City had no water quality violations in calendar year 2020.