



SANDY FIRE DISTRICT NO. 72

Fire Prevention Division

17460 Bruns Avenue 📍 PO Box 518 Sandy, Oregon 97055
Business Phone: 503.668.8093 📠 Facsimile: 503.668.7941 🌐 www.sandyfire.org

Mount Hood Farmer's Market Use Period - May 19 through October 20, 2023

Responsible Party – Neal Hatley (704) 506-0094 or nealh@antfarmyouthservices.com

Conditions for Mount Hood Farmer's Market:

- **3103.7 Inspections.** Periodic inspections to be conducted by the owner or owner's agent to make certain that operations continue to comply with all requirements.
- **3103.1 General.** Tents/canopies (no sides allowed) placed side by side are not to exceed an aggregate area of 700 square feet without a fire break clearance that is a minimum 12 feet wide and free from guy ropes or other obstructions.
- **3103.12 Means of egress.** Maintain a minimum aisle width of not less than 44 inches under the Mount Hood Farmer's Market tent.
- **3106.4.4 Portable fire extinguishers.** A minimum of one 2A-10BC fire extinguisher to be located within 75 feet travel distance of the Mount Hood Farmer's Market tent. Portable fire extinguisher(s) to be placed conspicuously so its location is visible and accessible in the event of an emergency.
- **3106.4.5 Smoking.** Smoking shall be permitted only in designated areas. "No Smoking" signs are to be conspicuously posted on and near the Mount Hood Farmer's Market tent area.
- **3106.4.7 Combustible refuse.** Combustible refuse shall be kept in noncombustible containers with tight-fitting or self-closing lids. Combustible refuse shall be removed from the event site at regular intervals to prevent an unsafe accumulation within the event site.
- **3106.5.1 Separation from tents or structures.** Cooking appliances or devices that produce sparks or grease-laden vapors or flying embers (firebrands) shall not be used within 20 feet of a tent or temporary structure.
- **3107.4 Open or exposed flame.** Open flame or other devices emitting flame, fire, or heat or any flammable or combustible liquids, gas, charcoal, or any other unapproved devices shall not be permitted inside or located within 20 feet of any tent/canopy or structures while open to the public unless approved by the Fire Marshal.
- **3107.16 Separation of generators.** Generators and other internal combustion power sources shall be separated from tents/canopies by not less than 20 feet and shall be isolated from contact with the public by fencing, enclosure, or other approved means.
- **604.5 Extension cords.** Extension cords, if used, are to be listed for outdoors and plugged directly into an approved receptacle and except for approved multiplug extension cord, shall serve only one portable appliance.